

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Fuse-holder

Name and address of the applicant

Mersen France SB S.A.S.
15 Rue Jacques de Vaucanson, 69720 SAINT BONNET DE
MURE
FRANCE

Name and address of the manufacturer

Mersen France SB S.A.S.
15 Rue Jacques de Vaucanson, 69720 SAINT BONNET DE
MURE
FRANCE

Name and address of the factory

Mersen France SB S.A.S.
15 Rue Jacques de Vaucanson, 69720 SAINT BONNET DE
MURE
FRANCE

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

Ue: 1000V DC; Ie: 32A; size: 10x38

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

CUS101(I)HEL

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60269-1:2006
IEC 60269-1:2006/AMD1:2009
IEC 60269-1:2006/AMD2:2014
IEC 60269-2:2013
IEC 60269-2:2013/AMD1:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

250082-TL3-1 / 250082-TL3-2

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierung Produkte / Certification Products

Date: 2018-07-23

Signature:

R. Nickel