



中国国家强制性产品认证证书

证书编号：2024010308649255

认证委托人名称及地址

Mersen France SB S. A. S.
15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

生产者名称及地址

Mersen France SB S. A. S.
15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

生产企业名称及地址

Mersen France SB S. A. S.
15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

产品名称和系列、型号、规格

半导体设备保护用熔断体
D70SF120V□□; Un: DC1200V; In:
20A, 25A, 32A, 40A, 50A, 63A, 80A, 100A, 125A, 160A, 200A, 215A; 额定分断能力:
100kA; 分断范围和使用类别:aR; 型号解释见附页

产品标准和技术要求

GB/T 13539.4-2016

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024) 的要求，特发此证。

发证日期：2024年06月27日 有效期至：2029年06月26日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站（www.cnca.gov.cn）查询。



签发：

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号：2024010308649255

证书附页：第 1 页 共 1 页

型号的解释：

D □ SF □ □ QF example D70SF120V215QF
1 2 3 4 5 6

1 : D , means square body fuse for semiconductor protection

2 : □ , Fuse size 70

3 : SF , breaking range and utilization category aR

4 : □ , rated voltage 1200 divided by ten

5 : □ , rated current

6 : QF , suffix for end connection,

may be followed by “B” for salt spray atmosphere finition or by“M” with monitoring

本页为证书附页，应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010308649255

NAME AND ADDRESS OF THE APPLICANT

Mersen France SB S.A.S.
15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

NAME AND ADDRESS OF THE MANUFACTURER

Mersen France SB S.A.S.
15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

NAME AND LOCATION OF THE FACTORY

Mersen France SB S.A.S.
15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

PRODUCT NAME,MODEL AND SPECIFICATION

SEMICONDUCTOR PROTECTION FUSES

D70SF120V□□ ; Un: DC1200V ; In: 20A,25A,32A,40A,50A,63A,80A,100A,125A,160A,200A,215A ;
Rated breaking capacity: 100kA ; Breaking Range and Utilization Category:aR ; See the Appendix

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 13539.4-2016

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Jun.27,2024

Valid until: Jun.26,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2024010308649255

Appendix: Page 1 of 1

Type description:

D □ SF □ □ QF example D70SF120V215QF
1 2 3 4 5 6

1 : D , means square body fuse for semiconductor protection

2 : □ , Fuse size 70

3 : SF , breaking range and utilization category aR

4 : □ , rated voltage 1200 divided by ten

5 : □ , rated current

6 : QF , suffix for end connection,

may be followed by “B” for salt spray atmosphere finition or by“M” with monitoring

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.