



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010308649238

NAME AND ADDRESS OF THE APPLICANT

Mersen France SB S.A.S.
15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

NAME AND ADDRESS OF THE MANUFACTURER

Mersen France SB S.A.S.
15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

NAME AND LOCATION OF THE FACTORY

Nolam Tunisia
rue de Nabeul lot n°4 zone industrielle de M'Ghira ,Tunis,Tunisie

PRODUCT NAME,MODEL AND SPECIFICATION

Fuse-links for the protection of semiconductor devices
FD20GB100V□(T),FD20GC100V□(T);Un=DC1000V;
In:FD20GB100V□(T):6A,8A,10A,12A,16A,20A,25A,32A;FD20GC100V□(T):40A,50A,63A;I1=50kA
;Breaking Range and Utilization Category:gR

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 13539.4-2016

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Jun.27,2024

Valid until: Jun.26,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2024010308649238

Appendix : Page 1 of 2

Type description:

FD20□100V□□

Example : FD20GB100V12T or FD20GC100V40T

FD: means Protistor French ferrule for DC applications

20: means the diameter of the fuse for a length of 127 mm

□: GB or GC: curve type gR (B or C, internal codification by Development, extend new range)

100V: means rated voltage 1000 volts

□: means the current nominal rating of fuse in amps

□: Blank or T means that the fuse has a striker

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2024010308649238

Appendix : Page 2 of 2

分断能力	型号	电流
1000V DC 50 kA	FD20GB100V6T	6
	FD20GB100V8T	8
	FD20GB100V10T	10
	FD20GB100V12T	12
	FD20GB100V16T	16
	FD20GB100V20T	20
	FD20GB100V25T	25
	FD20GB100V32T	32
	FD20GC100V40T	40
	FD20GC100V50T	50
	FD20GC100V63T	63
	FD20GB100V6	6
	FD20GB100V8	8
	FD20GB100V10	10
	FD20GB100V12	12
	FD20GB100V16	16
	FD20GB100V20	20
	FD20GB100V25	25
	FD20GB100V32	32
	FD20GC100V40	40
FD20GC100V50	50	
FD20GC100V63	63	

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.