



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010308649239

NAME AND ADDRESS OF THE APPLICANT

Mersen France SB S.A.S.
15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

NAME AND ADDRESS OF THE MANUFACTURER

Mersen France SB S.A.S.
15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

NAME AND LOCATION OF THE FACTORY

Nolam Tunisia
rue de Nabeul lot n°4 zone industrielle de M'Ghira ,Tunis,Tunisie

PRODUCT NAME,MODEL AND SPECIFICATION

Fuse-links for the protection of semiconductor devices
FD20GB150V□(T),FD20GD150V□;Un=DC1500V;
In:FD20GB150V□(T):0.8A,1A,1.5A,2A,3.15A,4A,5A;
FD20GD150V□:6A,8A,10A,12A,16A,20A,25A;I1=30kA;Breaking Range and Utilization Category:gR

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 13539.4-2016

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Jun.27,2024

Valid until: Jun.26,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2024010308649239

Appendix : Page 1 of 2

型号解释:

FD20□150V□□

Example : FD20GB150V5T or FD20GD150V25

FD: means Protistor French ferrule for DC applications

20: means the diameter of the fuse for a length of 127 mm

□: GB or GD: curve type gR (B or D, internal codification by Development, extend new range)

150V: means rated voltage 1500 volts

□: means the current nominal rating of fuse in amps

□: Blank or T means that the fuse has a striker

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2024010308649239

Appendix : Page 2 of 2

1500V DC 30kA	FD20GB150V0.8	0.8
	FD20GB150V1	1
	FD20GB150V1.5	1.5
	FD20GB150V2	2
	FD20GB150V3.15	3.15
	FD20GB150V4	4
	FD20GB150V5	5
	FD20GD150V6	6
	FD20GD150V8	8
	FD20GD150V10	10
	FD20GD150V12	12
	FD20GD150V16	16
	FD20GD150V20	20
	FD20GD150V25	25
	FD20GB150V0.8T	0.8
	FD20GB150V1T	1
	FD20GB150V1.5T	1.5
	FD20GB150V2T	2
	FD20GB150V3.15T	3.15
	FD20GB150V4T	4
	FD20GB150V5T	5

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.