



中国国家强制性产品认证证书

证书编号: 2024010302649252

认证委托人名称及地址

Mersen France SB S. A. S.

15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

生产者名称及地址

Mersen France SB S. A. S.

15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

生产企业名称及地址

Nolam Tunisia

rue de Nabeul lot n° 4 zone industrielle de M' Ghira ,Tunis,Tunisie

产品名称和系列、型号、规格

熔断器式隔离器

US27:Uimp: 8kV;Ui:800V;lth:140A;Ue: AC800V(AC-20B)、DC660V(DC-20B);Ie:140A;Iq:100kA;
使用类别:AC-20B, DC-20B;极数:1P、1P+N、2P、3P、3P+N;适用频率:50/60Hz;防护等级:IP20;
配用的辅助触头:1NC 或 1NO;lth: 5A;AC-12: 220V/5A, DC-13: 120V/0.2A;型号解释见附页

产品标准和技术要求

GB/T 14048.3-2017

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024)的要求,特发此证。

发证日期: 2024年06月27日 有效期至: 2029年06月26日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,
也可在认监委网站(www.cnca.gov.cn)查询。



签发:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号：2024010302649252

证书附页：第 1 页 共 1 页

型号解释：

CMS27 □ □ □

① ② ③ ④

①: Fuse diameter used 使用的熔体尺寸

②: Number of poles 极数 : 1P:1; 2P:2; 3P:3

③: N:Neutral;带中性极

Blank:without Neutral;不带中性极

④: I:Indicator ; 带指示灯

M: Microswitch; 带微动开关

MI: Microswitch and Indicator 带指示灯和微动开关

BLANK: without Microswitch and Indicator; 空白: 无指示灯和微动开关

本页为证书附页，应与证书主页同时使用。



中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010302649252

NAME AND ADDRESS OF THE APPLICANT

Mersen France SB S.A.S.
15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

NAME AND ADDRESS OF THE MANUFACTURER

Mersen France SB S.A.S.
15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

NAME AND LOCATION OF THE FACTORY

Nolam Tunisia
rue de Nabeul lot n°4 zone industrielle de M'Ghira ,Tunis,Tunisie

PRODUCT NAME,MODEL AND SPECIFICATION

Fuse Disconnecter

US27:Uimp: 8kV;Ui:800V;Ith:140A;Ue: AC800V(AC-20B)、 DC660V(DC-20B);Ie:140A;Iq:100kA;Utilization
Category:AC-20B, DC-20B;Poles: 1P、 1P+N、 2P、 3P、 3P+N;Applicable frequency : 50/60Hz;IP20;Attached Auxiliary
Contacts:1NC or 1NO;Ith : 5A;AC-12 : 220V/5A, DC-13 : 120V/0.2A;See the appendix

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.3-2017

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Jun.27,2024

Valid until: Jun.26,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2024010302649252

Appendix : Page 1 of 1

Type description :

CMS27 □ □ □

① ② ③ ④

①: Fuse diameter used 使用的熔体尺寸

②: Number of poles 极数 : 1P:1; 2P:2; 3P:3

③: N:Neutral;带中性极

Blank:without Neutral;不带中性极

④:I:Indicator ; 带指示灯

M: Microswitch; 带微动开关

MI: Microswitch and Indicator 带指示灯和微动开关

BLANK: without Microswitch and Indicator; 空白: 无指示灯和微动开关

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.