



# ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **25214-001-04**

Valid from: 2018 07 21  
until: 2020 07 21

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **Mersen France SB SAS**  
15 Rue Jacques de Vaucanson  
69720 Saint Bonnet de Mure  
France

Product: **Switch-disconnector-fuse**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **2.03.01010.1.0/D0 LINO CUR**

**Österreichischer Verband für Elektrotechnik**  
Head of Testing & Certification



Digitally signed by W. Martin  
Email=w.martin@ove.at

Dipl.-Ing. W. Martin

Vienna, 2018 06 20

## OVE Testing & Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under [www.bmdw.gv.at/akkreditierung](http://www.bmdw.gv.at/akkreditierung).





**Manufacturer:**

Mersen France SB SAS  
15 Rue Jacques de Vaucanson  
69720 Saint Bonnet de Mure  
France

**Factory location(s):**

Mersen France SB SAS  
15 Rue Jacques de Vaucanson  
69720 Saint Bonnet de Mure  
France

**Tested and certified according to:**

ÖVE/ÖNORM EN 60947-1:2015-10-01  
OVE EN 60947-3:2017-03-01

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**.

**Product: Switch-disconnector-fuse**

**Type designation:**

**Rating:**

**Trademark:**

**05861.020000**

Rated voltage: AC 230/400 V  
Rated current: 20 A  
1P  
AC22B, IP20

MERSEN

**05861.025000**

Rated voltage: AC 230/400 V  
Rated current: 25 A  
1P  
AC22B, IP20

MERSEN

**05861.035000**

Rated voltage: AC 230/400 V  
Rated current: 35 A  
1P  
AC22B, IP20

MERSEN

**OVE Testing & Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under [www.bmdw.gv.at/akkreditierung](http://www.bmdw.gv.at/akkreditierung).





<b>05861.050000</b> Rated voltage: AC 230/400 V Rated current: 50 A 1P AC22B, IP20	MERSEN
<b>05861.063000</b> Rated voltage: AC 230/400 V Rated current: 63 A 1P AC22B, IP20	MERSEN
<b>05862.020000</b> Rated voltage: AC 400 V Rated current: 20 A 2P AC22B, IP20	MERSEN
<b>05862.025000</b> Rated voltage: AC 400 V Rated current: 25 A 2P AC22B, IP20	MERSEN
<b>05862.035000</b> Rated voltage: AC 400 V Rated current: 35 A 2P AC22B, IP20	MERSEN
<b>05862.050000</b> Rated voltage: AC 400 V Rated current: 50 A 2P AC22B, IP20	MERSEN
<b>05862.063000</b> Rated voltage: AC 400 V Rated current: 63 A 2P AC22B, IP20	MERSEN
<b>05863.020000</b> Rated voltage: AC 400 V Rated current: 20 A 3P AC22B, IP20	MERSEN
<b>05863.025000</b> Rated voltage: AC 400 V Rated current: 25 A 3P AC22B, IP20	MERSEN

### OVE Testing & Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under [www.bmdw.gv.at/akkreditierung](http://www.bmdw.gv.at/akkreditierung).





**05863.035000**

Rated voltage: AC 400 V  
Rated current: 35 A  
3P  
AC22B, IP20

MERSEN

**05863.050000**

Rated voltage: AC 400 V  
Rated current: 50 A  
3P  
AC22B, IP20

MERSEN

**05863.063000**

Rated voltage: AC 400 V  
Rated current: 63 A  
3P  
AC22B, IP20

MERSEN

**05861.063100**

Rated voltage: AC 230 V  
Rated current: 63 A  
1P+N  
AC22B, IP20

MERSEN

**05863.063100**

Rated voltage: AC 400 V  
Rated current: 63 A  
3P+N  
AC22B, IP20

MERSEN

---

**OVE Testing & Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under [www.bmdw.gv.at/akkreditierung](http://www.bmdw.gv.at/akkreditierung).

